

# कार्यालय-डा0 भीमराव अम्बेडकर सामाजिक परिवर्तन स्थल (आन्तरिक),

प्रशासनिक भवन (आन्तरिक), गोमती नगर, लखनऊ।

(स्मारकों, संग्रहालयों, संस्थाओं, पार्कों व उपवनों आदि की प्रबन्धन सुरक्षा एवं अनुरक्षण समिति लखनऊ।)

09

पत्रांक :- 202 / प्र0/सा0परि0स्थ0-01/2023

दिनांक : 06 / 02 / 2023

## कोटेशन आमन्त्रण-सूचना

डा0 भीमराव अम्बेडकर सामाजिक परिवर्तन स्थल (आन्तरिक क्षेत्र) गोमती नगर, लखनऊ के पार्क/परिक्षेत्र के जोन नं0 04 की वी0वी0आई0पी0 गेट साइड की वॉटर बॉडी/फाउण्टेन हेतु नया स्टार्टर पैनल स्थापित कराने सम्बन्धित कार्य कराये जाने हेतु लखनऊ विकास प्राधिकरण में पंजीकृत फर्मों से निम्न विवरण के अनुसार कोटेशन आमंत्रित किये जाते हैं:-

| Sr. No. | Schedule Item No | Description of Item  | Unit | Qty. |
|---------|------------------|--|------|------|
| 1-      | 801              | Supply and creton of factory fabricated an wired metal clad dust and vermin proof floor mounting panel. TPN swith board complete with the following HRC type heavy duty TPN fuse switches with fuses and instrumentchamber etc. Complete in all respects. The instrument chamber shall be separate and shall comprise of flush type ammeter, voltmeter, selector swiths for ammeter and voltmeter, instrument fuses, current transformer etc. The board shall have suitable capacity electroic aluminium busbars as per IS8623 istulate with heat shrink sleeving and mountend on non hygroscopic supports such as CMC/DMC support with deteachable side cover and shall be suitable for extension on tht side. The switches shall be complete with suitable cable end boxes, reverse entery boxes in case of pedestal type. Cable sockets, compression glands and indicating lamp on incoming Etc.<br>The job includes the grouting of the board as per direction of Engineer-in-Charge. All outgoing switches of 100 Amp. And above will be provided with ampere metre current transformers and selector switches and instrument fuses etc. The switches board shall be fabricated with CRCA sheet with a minimum thickness of 1.6 mm/2mm. Cubicle type switch board shall be of cat A B &-II and pedestal type for Cat-B an C only. |      |      |
|         |                  | Incoming 100 Amp. TPN-1. No  |      |      |
|         |                  | Outgoing (b) 32 Amp. TPN-3 Nos. (Cat. B. Cubicle Type)   |      |      |
| 2-      | 1019             | S&F of 32 Amp 4 pole MCB (10KA)C Curve (CAT A)   | No.  | 01   |
| 3-      | 1021 (D)         | S&F of 125 Amp 4 pole MCCB (25 KA) thermal Magnetic release (CAT A)  | No.  | 01   |

उपरोक्त कार्य हेतु इच्छुक फर्म दिनांक 09.02.2023 को अपरान्ह 03.00 बजे तक अपनी कोटेशन पंजीकृत प्रमाण पत्र की छायाप्रति संलग्न करते हुए सीलबन्द लिफाफे में प्रबन्धक कार्यालय, डा0 भीमराव अम्बेडकर सामाजिक परिवर्तन स्थल, आन्तरिक क्षेत्र गोमती नगर, लखनऊ को प्रेषित करें, प्राप्त कोटेशन में से न्यूनतम दर वाली फर्म को कार्य करने हेतु कार्यादेश जारी किया जायेगा। कोटेशन स्वीकृत/निरस्त करने का अधिकार सक्षम अधिकारी के अधीन होगा।

(यमन हफीज)  
प्रबन्धक

### प्रतिलिपि :

1. मुख्य प्रबन्धक महोदय को सादर अवलोकनार्थ।
2. प्रबन्धक (वित्त/अनुरक्षण) को सूचनार्थ।
3. सर्वर एवं नेटवर्क इंजीनियर को इस आशय से प्रेषित कि उक्त कोटेशन आमन्त्रण सूचना को स्मारक समिति की वेबसाइट पर अपलोड सम्बन्धित कार्यवाही हेतु।
4. नोटिस बोर्ड।

प्रबन्धक